



IMPORTANT SAFE GUARDS:

- THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED.
- DISCONNECT POWER BEFORE BEGINNING INSTALLATION.
- FIXTURE MUST BE INSTALLED IN COMPLIANCE WITH THE NATIONAL ELECTRIC CODE AND ANY LOCAL CODES.
- TO BE INSTALLED ONLY BY A QUALIFIED ELECTRICIAN.
- PROPER GROUNDING IS REQUIRED TO INSURE PERSONAL SAFETY.
- READ ALL FIXTURE MARKINGS AND LABELS TO ENSURE CORRECT INSTALLATION OF FIXTURE.
- RISK OF FIRE, USE A MINIMUM OF 90C SUPPLY CONNECTORS.
- MAXIMUM MOUNTING HEIGHT OF 8FT. WHEN AN EMERGENCY PACK IS PROVIDED


INSTALLATION INSTRUCTIONS:

1. REMOVE (4) FASTENERS AND OPEN HOUSING.




3. REMOVE (4) FASTENERS TO REMOVE DRIVER COVER(S) OR WIRE COVER DEPENDING ON CONFIGURATION.

4. REMOVE THE KNOCKOUT(S) WHERE THE ELECTRICAL CONNECTIONS WILL BE MADE.




CONFIGURATION A




CONFIGURATION B

5. SECURE HOUSING USING THE (4) MOUNTING HOLES ON THE BACK.




6. MAKE ANY NECESSARY ELECTRICAL CONNECTIONS VIA AVAILABLE KNOCKOUT(S).


7. SECURE DRIVER COVER(S) OR LED TRAY DEPENDING ON CONFIGURATION.




CONFIGURATION A




CONFIGURATION B



LAM1



LAM2



LAM4

IMPORTANT SAFE GUARDS:

- THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED.
- DISCONNECT POWER BEFORE BEGINNING INSTALLATION.
- FIXTURE MUST BE INSTALLED IN COMPLIANCE WITH THE NATIONAL ELECTRIC CODE AND ANY LOCAL CODES.
- TO BE INSTALLED ONLY BY A QUALIFIED ELECTRICIAN.
- PROPER GROUNDING IS REQUIRED TO INSURE PERSONAL SAFETY.
- READ ALL FIXTURE MARKINGS AND LABELS TO ENSURE CORRECT INSTALLATION OF FIXTURE.
- RISK OF FIRE, USE A MINIMUM OF 90C SUPPLY CONNECTORS.
- MAXIMUM MOUNTING HEIGHT OF 8FT. WHEN AN EMERGENCY PACK IS PROVIDED

INSTALLATION INSTRUCTIONS:

8. RE-INSTALL HOUSING FRAME WITH (4) FASTENERS PROVIDED TO COMPLETE INSTALLATION.

